

Home Liquefied Petroleum Gas (LPG) Safety Guidelines



New Construction Placement Regulations

Starting from July 1, 2022, for buildings applying for construction permits, gas cylinders should be placed outdoors.

Existing Building Placement Regulations

To enhance the safety of using LPG at home, it is recommended that gas cylinders in existing buildings be moved outdoors.

Indoor Storage Regulations

For LPG usage below 10 kilograms, gas cylinders can be placed indoors.

Relevant Safety Measures

Whether placed indoors or outdoors, it is recommended to implement safety measures, such as securing containers to prevent tipping, securing pipelines to prevent detachment, and installing gas leak detectors.

Safety Measures to Prevent Pipeline Detachment

Gas Leak Detectors

Preventing Container Tipping

